





HORIZONTAL STEAM - HOT WATER UNIT HEATER MODINE



Model	Steam MBtuH	Water MBtuH	Water Flow	Press Drop	CFM	HP	Pipe Conn.	Max Hgt.	"A"	"B"	"C"	"D"
HS-24	24	16.6	1.7	0.8	370	$\frac{1}{25}$	$\frac{3}{4}$	9	12 $\frac{1}{2}$	12 $\frac{1}{2}$	6	6
HS-33	33	21.6	2.2	0.2	360	$\frac{1}{25}$	1 $\frac{3}{4}$	10	17 $\frac{1}{2}$	17 $\frac{1}{2}$	8 $\frac{3}{4}$	6 $\frac{1}{2}$
HS-47	47	30.8	3.2	0.3	730	$\frac{1}{12}$	1 $\frac{3}{4}$	12	17 $\frac{1}{2}$	17 $\frac{1}{2}$	8 $\frac{3}{4}$	8
HS-63	63	44.8	4.6	0.8	1120	$\frac{1}{12}$	1 $\frac{3}{4}$	14	22	22	8 $\frac{3}{4}$	8
HS-86	86	62.6	6.5	1.4	1340	$\frac{1}{8}$	1 $\frac{3}{4}$	15	22	22	8 $\frac{3}{4}$	8
HS-108	108	81	8.4	3.2	2010	$\frac{1}{8}$	1 $\frac{3}{4}$	17	27 $\frac{1}{4}$	27 $\frac{1}{4}$	9 $\frac{3}{4}$	7 $\frac{1}{2}$
HS-121	121	91.9	9.5	4	1775	$\frac{1}{6}$	1 $\frac{3}{4}$	16	27 $\frac{1}{4}$	27 $\frac{1}{4}$	9 $\frac{3}{4}$	7 $\frac{1}{2}$
HS-165	165	131.9	13.7	7.9	3240	$\frac{1}{3}$	1 $\frac{3}{4}$	19	30 $\frac{1}{2}$	30 $\frac{1}{2}$	9 $\frac{3}{4}$	9 $\frac{1}{2}$
HS-193	193	145.2	15.1	2	2900	$\frac{1}{3}$	1 $\frac{3}{4}$	18	38 $\frac{1}{2}$	38 $\frac{1}{2}$	9 $\frac{3}{4}$	9 $\frac{1}{2}$